



C o u n t y o f S a n L u i s O b i s p o

## **GENERAL SERVICES AGENCY**

Janette D. Pell, Director

Helen McCann, Department Administrator

### **REQUEST FOR PROPOSAL PS- #1102**

### **LOPEZ 18" PIPELINE CLEANING PROJECT**

### **QUESTIONS AND ANSWERS**

October 26, 2010

---

#### **QUESTION:**

The Scope and Conditions requires that the Contractor provide two 12-foot lanes for traffic in both directions. Will coned delineation be acceptable or will flaggers be required 24 hours per day during the time of construction?

#### **ANSWER:**

Two 12-foot traffic lanes provide adequate 24-hour emergency access; therefore, 24-hour flagging will not be required. Contractor shall propose the extent of flagging, if any, and delineation in his Traffic Control Plan. The District, the City of Pismo Beach and the City of Arroyo Grande will review the Contractor's traffic control plan for final approval.

---